



CHH EM1.0 - Environmental Monitoring Results

Period: 9/5/2013 - 1/11/2013

Site: **Glenreagh NSW**

Environment Protection Licence No.

11413

Site Name -As it appears on the licence

COFFS HARBOUR HARDWOODS

Site Address -As it appears on the licence

161 Tallawudjah Creek Road, GLENREAGH, NSW, 2450

Location	Frequency	Test	Limit		Units	Sample Date	Result	Comments
			min	max				

NRR = No Result Recorded

Water Monitoring Data

Point 1	6 Monthly	Chromium		0.002	mg/L	9/05/2013	<.003	
		Copper		0.002	mg/L	9/05/2013	<.004	
		Arsenic		0.012	mg/L	9/05/2013	<.018	
		Boron		0.18	mg/L	9/05/2013	<.027	
		Total Suspended Solids		50	mg/L	9/05/2013	NR	no result
		pH	6.5	8.5	pH	9/05/2013	6.8	
Point 2	6 Monthly	Chromium		0.002	mg/L	9/05/2013	<.003	
		Copper		0.002	mg/L	9/05/2013	<.004	
		Arsenic		0.012	mg/L	9/05/2013	<.018	
		Boron		0.18	mg/L	9/05/2013	0.081	
		Total Suspended Solids		50	mg/L	9/05/2013	NR	no result
		pH	6.5	8.5	pH	9/05/2013	6.8	
Point 3	6 Monthly	Chromium		0.002	mg/L	9/05/2013	<.003	
		Copper		0.002	mg/L	9/05/2013	<.004	
		Arsenic		0.012	mg/L	9/05/2013	<.018	
		Boron		0.18	mg/L	9/05/2013	0.073	
		Total Suspended Solids		50	mg/L	9/05/2013	NR	no result
		pH	6.5	8.5	pH	9/05/2013	6.7	
Point 4	6 Monthly	Chromium		0.002	mg/L	9/05/2013	<.003	
		Copper		0.002	mg/L	9/05/2013	<.004	
		Arsenic		0.012	mg/L	9/05/2013	0.021	
		Boron		0.18	mg/L	9/05/2013	0.059	
		Total Suspended Solids		50	mg/L	9/05/2013	NR	no result
		pH	6.5	8.5	pH	9/05/2013	6.4	
Point 5	6 Monthly	Chromium		0.002	mg/L	9/05/2013	<.003	
		Copper		0.002	mg/L	9/05/2013	<.004	
		Arsenic		0.012	mg/L	9/05/2013	<.018	
		Boron		0.18	mg/L	9/05/2013	0.033	